

To the Public Utility Commission of Texas

# ERCOT Wholesale Electricity Market Monthly Report


Wednesday, January 10, 2024

Potomac Economics, Ltd.  
Independent Market Monitor

<b>1</b>	<b>ERCOT-wide Average Energy Prices DA vs. RT</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>2</b>	<b>Load Zone Load Statistics</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>3</b>	<b>Load Zone Monthly Average Energy Prices DA vs RT</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>4</b>	<b>ERCOT-wide Monthly Implied Heat Rates DA vs RT</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>5</b>	<b>Load Zone Monthly Implied Heat Rates DA vs RT</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>6</b>	<b>Daily ORDC Reserve Adder Avg. Value and Duration</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>9</b>	<b>Monthly Ancillary Services Required MW</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>10</b>	<b>Hourly Average of Ancillary Services Required MW</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>11</b>	<b>Monthly Average Ancillary Services Price</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>12</b>	<b>Monthly Average A/S Cost per MWh Load</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>13</b>	<b>Ercot-wide Cumulative Peaker Net Margin</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>14</b>	<b>DA vs. RT Load Forecast Error by Hour Ending</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>15</b>	<b>Monthly Average of Wind Generation by Hour Ending</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>16</b>	<b>Monthly Average of Solar Generation by Hour Ending</b>	<a href="#">chart</a>	<a href="#">table</a>
<b>17</b>	<b>RT Constraint Rankings</b>		<a href="#">table</a>
	- Top 10 Constraints by Total Congestion Value	<a href="#">chart</a>	
	- Top 10 Constraints by Binding Frequency	<a href="#">chart</a>	
<b>18</b>	<b>DA Constraint Rankings</b>		<a href="#">table</a>
	- Top 10 Constraints by Total Congestion Value	<a href="#">chart</a>	
	- Top 10 Constraints by Binding Frequency	<a href="#">chart</a>	
<b>19</b>	<b>CRR Pairs by Monthly Auction Value Rankings</b>		<a href="#">table</a>
	- Top 10 PTP Obligations by Total Transaction Value	<a href="#">chart</a>	
	- Top 10 PTP Options by Total Transaction Value	<a href="#">chart</a>	





# ERCOT-wide Average Energy Prices DA vs RT

(avg. DA & RT SPPs weighted by Real Time Settlement Loads)



# Load Zone Load Statistics





(Nodal load zone made comparable to zonal system Load Zone definitions\*)



Note: \* Zonal load zone definition vs. Nodal comparable load zone definition: LZ\_Houston=LZ\_Houston; LZ\_West=LZ\_West; LZ\_North=(LZ\_North,LZ\_RAYBN); LZ\_South=(LZ\_South,LZ\_CPS,LZ\_AEN,LZ\_LCRA)

# Load Zone Monthly Average Energy Price DA vs RT


(avg. DA & RT SPPs weighted by Real Time Settlement Loads)  
 (Nodal load zone made comparable to zonal sytem Load Zone definitions\*)



**Note:** \* Zonal load zone definition vs. Nodal comparable load zone definition: LZ\_Houston=LZ\_Houston; LZ\_West=LZ\_West; LZ\_North=(LZ\_North,LZ\_RAYBN); LZ\_South=(LZ\_South,LZ\_CPS,LZ\_AEN,LZ\_LCRA)





# ERCOT-wide Monthly Implied Heat Rate DA vs RT

(avg. heat rates weighted by Real Time Settlement Loads)



# Load Zone Monthly Implied Heat Rate DA vs RT

(avg. heat rates weighted by Real Time Settlement Loads)  
 (Nodal load zone made comparable to zonal sytem Load Zone definitions\*)




**Note:** \* Zonal load zone definition vs. Nodal comparable load zone definition: LZ\_Houston=LZ\_Houston; LZ\_West=LZ\_West; LZ\_North=(LZ\_North,LZ\_RAYBN); LZ\_South=(LZ\_South,LZ\_CPS,LZ\_AEN,LZ\_LCRA)

# Daily ORDC Adders Average Values and Interval Duration






Dec-2023

RDP Adder RS Adder

Daily Averages








# Monthly Average of Ancillary Services Required MW










# Hourly Average of Ancillary Services Required MW




# Monthly Average Ancillary Services Price


(weighted by A/S Quantities Required)




# Monthly Average A/S Cost per MWh Load




# ERCOT-wide Cumulative Peaker Net Margin




# DA vs. RT Load Forecast Error by Hour Ending



# Monthly Average of Wind Generation by Hour Ending




# Monthly Average of Solar Generation by Hour Ending



# RT Congestion Constraint Rankings - 1

## Top 10 Constraints by Total Congestion Value - 2023


Congestion Rent in \$ million






# RT Congestion Constraint Rankings - 2

## Top 10 Constraints by Binding Frequency - 2023




# DA Congestion Constraint Rankings - 1

## Top 10 Constraints by Total Congestion Value - 2023




# DA Congestion Constraint Rankings - 2

## Top 10 Constraints by Binding Frequency - 2023




# Top 10 CRR Pairs Ranked by Monthly Auction Values - 1

## Top 10 PTP Obligations by Total Transaction Value - 2023



# Top 10 CRR Pairs Ranked by Monthly Auction Values - 2

## Top 10 PTP Options by Total Transaction Value - 2023



ERCOT-wide Avg. Energy Price - DA vs. RT			
year	month	dam_spp	rtm_spp
2022	1	\$ 34.35	\$ 31.53
	2	\$ 43.07	\$ 56.44
	3	\$ 40.77	\$ 36.50
	4	\$ 59.57	\$ 56.75
	5	\$ 100.33	\$ 105.11
	6	\$ 90.49	\$ 70.68
	7	\$ 136.65	\$ 164.42
	8	\$ 107.33	\$ 93.70
	9	\$ 74.55	\$ 67.90
	10	\$ 51.60	\$ 53.24
	11	\$ 46.66	\$ 43.59
	12	\$ 77.92	\$ 68.72
2023	1	\$ 28.02	\$ 26.68
	2	\$ 23.83	\$ 21.95
	3	\$ 29.90	\$ 31.20
	4	\$ 27.58	\$ 24.45
	5	\$ 32.08	\$ 32.48
	6	\$ 88.69	\$ 75.44
	7	\$ 64.47	\$ 48.62
	8	\$ 306.37	\$ 224.46
	9	\$ 86.23	\$ 111.45
	10	\$ 37.83	\$ 31.83
	11	\$ 33.62	\$ 31.70
	12	\$ 23.31	\$ 23.94

Load Zone Load Statistics										
year	month	loadPEAK_Houston	loadPEAK_North	loadPEAK_South	loadPEAK_West	loadAVG_Houston	loadAVG_North	loadAVG_South	loadAVG_West	
2022	1	14,538	24,512	17,967	7,086	11,237	15,956	11,622	6,076	
	2	16,355	26,051	21,091	7,265	11,493	16,574	12,372	6,106	
	3	13,743	21,306	15,955	7,022	10,826	13,572	10,613	5,981	
	4	15,984	19,684	17,088	7,352	11,660	13,361	11,643	6,099	
	5	19,616	25,004	19,781	8,076	14,530	16,528	14,149	6,587	
	6	20,558	28,957	20,734	7,989	15,490	20,238	15,790	6,874	
	7	20,499	31,048	21,709	8,310	15,414	22,575	16,567	7,254	
	8	20,315	29,900	21,461	8,300	14,664	20,453	15,603	7,079	
	9	19,063	26,298	19,017	7,931	13,453	17,431	14,210	6,881	
	10	17,561	23,221	18,587	7,479	11,138	13,721	11,842	6,549	
	11	15,467	19,283	15,872	7,659	10,604	14,239	11,583	6,863	
	12	15,505	31,042	22,167	8,488	10,624	15,556	12,294	6,926	
2023	1	13,536	25,319	19,752	8,314	10,032	14,695	11,456	7,047	
	2	14,496	23,636	19,151	7,982	10,774	15,110	12,079	7,012	
	3	14,697	18,648	15,878	7,717	11,041	13,262	11,487	6,958	
	4	16,197	20,284	17,553	8,356	11,129	12,981	11,440	7,078	
	5	18,724	23,418	18,877	8,367	13,228	15,282	13,151	7,344	
	6	21,220	29,468	23,132	9,058	15,728	19,420	16,250	7,856	
	7	21,818	30,724	22,696	9,243	16,542	21,768	17,230	8,198	
	8	22,904	32,117	23,551	9,579	17,535	23,675	17,930	8,386	
	9	22,170	31,357	22,680	9,310	15,835	19,342	16,426	8,045	
	10	18,731	25,315	20,730	8,732	12,624	14,551	12,768	7,616	
	11	15,214	20,691	14,797	8,634	11,045	13,625	11,144	7,692	
	12	13,162	20,234	16,044	8,830	11,014	14,380	11,339	7,985	

Load Zone Monthly Average Energy Price - DA vs. RT										
year	month	avgRTMp_Houston	avgRTMp_North	avgRTMp_South	avgRTMp_West	avgDAMp_Houston	avgDAMp_North	avgDAMp_South	avgDAMp_West	
2022	1	\$ 31.41	\$ 33.20	\$ 31.75	\$ 26.95	\$ 34.60	\$ 35.62	\$ 34.65	\$ 29.95	
	2	\$ 53.15	\$ 60.40	\$ 58.32	\$ 48.04	\$ 42.94	\$ 45.71	\$ 42.80	\$ 36.68	
	3	\$ 41.71	\$ 35.15	\$ 34.34	\$ 33.97	\$ 45.63	\$ 41.70	\$ 38.79	\$ 33.36	
	4	\$ 63.32	\$ 51.82	\$ 59.27	\$ 50.18	\$ 69.99	\$ 56.22	\$ 57.10	\$ 51.67	
	5	\$ 147.58	\$ 87.96	\$ 95.04	\$ 76.06	\$ 120.53	\$ 91.33	\$ 97.95	\$ 83.42	
	6	\$ 84.26	\$ 67.65	\$ 65.97	\$ 59.83	\$ 102.83	\$ 87.20	\$ 87.16	\$ 79.99	
	7	\$ 163.85	\$ 174.42	\$ 155.55	\$ 154.74	\$ 136.01	\$ 141.37	\$ 133.51	\$ 130.55	
	8	\$ 94.24	\$ 95.96	\$ 91.09	\$ 91.74	\$ 107.10	\$ 110.47	\$ 104.84	\$ 104.23	
	9	\$ 68.24	\$ 67.75	\$ 68.88	\$ 65.60	\$ 75.11	\$ 75.12	\$ 74.70	\$ 71.70	
	10	\$ 54.82	\$ 52.43	\$ 55.09	\$ 48.89	\$ 54.35	\$ 50.59	\$ 52.45	\$ 47.48	
	11	\$ 46.07	\$ 43.02	\$ 43.65	\$ 40.85	\$ 49.28	\$ 46.58	\$ 46.69	\$ 42.74	
	12	\$ 62.10	\$ 74.12	\$ 68.82	\$ 66.56	\$ 73.77	\$ 81.46	\$ 82.01	\$ 69.09	
2023	1	\$ 23.47	\$ 26.48	\$ 25.55	\$ 33.49	\$ 25.89	\$ 27.48	\$ 26.48	\$ 34.71	
	2	\$ 20.03	\$ 19.93	\$ 23.08	\$ 27.30	\$ 22.98	\$ 23.49	\$ 23.47	\$ 26.49	
	3	\$ 27.01	\$ 25.68	\$ 30.49	\$ 49.53	\$ 27.54	\$ 24.88	\$ 29.70	\$ 43.56	
	4	\$ 22.22	\$ 21.37	\$ 22.07	\$ 37.41	\$ 27.18	\$ 23.91	\$ 27.33	\$ 35.31	
	5	\$ 33.09	\$ 30.37	\$ 31.09	\$ 38.29	\$ 33.33	\$ 30.28	\$ 30.50	\$ 36.38	
	6	\$ 73.11	\$ 77.43	\$ 79.23	\$ 67.36	\$ 88.76	\$ 89.95	\$ 92.38	\$ 77.80	
	7	\$ 50.90	\$ 50.27	\$ 46.09	\$ 44.97	\$ 65.72	\$ 65.87	\$ 63.46	\$ 60.36	
	8	\$ 228.13	\$ 238.94	\$ 211.98	\$ 202.41	\$ 307.67	\$ 320.15	\$ 302.38	\$ 273.14	
	9	\$ 106.05	\$ 121.38	\$ 111.69	\$ 97.73	\$ 82.99	\$ 91.23	\$ 86.59	\$ 79.87	
	10	\$ 31.00	\$ 28.73	\$ 31.55	\$ 39.56	\$ 37.26	\$ 35.12	\$ 38.02	\$ 43.62	
	11	\$ 30.16	\$ 29.08	\$ 30.70	\$ 40.00	\$ 32.36	\$ 31.57	\$ 32.36	\$ 40.87	
	12	\$ 20.64	\$ 20.19	\$ 21.42	\$ 38.83	\$ 20.94	\$ 20.11	\$ 21.59	\$ 34.76	



ERCOT-wide Monthly Implied Heat Rate - DA vs. RT						
year	month	gasprice	rtm_spp	HR_rtm	dam_spp	HR_dam
2022	1	\$ 4.01	\$ 31.53	7.86	\$ 34.35	8.56
	2	\$ 4.45	\$ 56.44	12.70	\$ 43.07	9.69
	3	\$ 4.53	\$ 36.50	8.06	\$ 40.77	9.00
	4	\$ 6.29	\$ 56.75	9.02	\$ 59.57	9.46
	5	\$ 7.83	\$ 105.11	13.43	\$ 100.33	12.81
	6	\$ 7.40	\$ 70.68	9.55	\$ 90.49	12.23
	7	\$ 6.78	\$ 164.42	24.24	\$ 136.65	20.15
	8	\$ 8.22	\$ 93.70	11.40	\$ 107.33	13.06
	9	\$ 7.03	\$ 67.90	9.66	\$ 74.55	10.61
	10	\$ 4.83	\$ 53.24	11.02	\$ 51.60	10.68
	11	\$ 4.16	\$ 43.59	10.49	\$ 46.66	11.23
	12	\$ 4.48	\$ 68.72	15.33	\$ 77.92	17.39
2023	1	\$ 2.65	\$ 26.68	10.07	\$ 28.02	10.58
	2	\$ 2.05	\$ 21.95	10.69	\$ 23.83	11.60
	3	\$ 2.08	\$ 31.20	15.00	\$ 29.90	14.37
	4	\$ 1.86	\$ 24.45	13.15	\$ 27.58	14.83
	5	\$ 1.96	\$ 32.48	16.59	\$ 32.08	16.39
	6	\$ 2.10	\$ 75.44	36.00	\$ 88.69	42.32
	7	\$ 2.36	\$ 48.62	20.63	\$ 64.47	27.36
	8	\$ 2.40	\$ 224.46	93.61	\$ 306.37	127.76
	9	\$ 2.40	\$ 111.45	46.39	\$ 86.23	35.89
	10	\$ 2.39	\$ 31.83	13.32	\$ 37.83	15.83
	11	\$ 2.30	\$ 31.70	13.81	\$ 33.62	14.65
	12	\$ 2.07	\$ 23.94	11.59	\$ 23.31	11.28

Load Zone Monthly Implied Heat Rate - DA vs. RT									
year	month	HRdam_Houston	HRdam_South	HRdam_North	HRdam_West	HRrtm_Houston	HRrtm_South	HRrtm_North	HRrtm_West
2022	1	8.62	8.64	8.88	7.46	7.83	7.91	8.27	6.72
	2	9.66	9.63	10.28	8.25	11.96	13.12	13.59	10.81
	3	10.08	8.56	9.21	7.37	9.21	7.58	7.76	7.50
	4	11.12	9.07	8.93	8.21	10.06	9.41	8.23	7.97
	5	15.40	12.51	11.67	10.66	18.85	12.14	11.24	9.72
	6	13.90	11.78	11.79	10.81	11.39	8.92	9.14	8.09
	7	20.05	19.68	20.84	19.25	24.16	22.93	25.71	22.81
	8	13.04	12.76	13.45	12.69	11.47	11.09	11.68	11.17
	9	10.69	10.63	10.69	10.20	9.71	9.80	9.64	9.33
	10	11.25	10.85	10.47	9.83	11.35	11.40	10.85	10.12
	11	11.86	11.24	11.21	10.28	11.09	10.50	10.35	9.83
	12	16.46	18.30	18.18	15.42	13.86	15.36	16.54	14.85
2023	1	9.77	9.99	10.37	13.10	8.86	9.64	10.00	12.64
	2	11.19	11.43	11.44	12.90	9.76	11.24	9.70	13.29
	3	13.24	14.28	11.96	20.94	12.98	14.65	12.34	23.81
	4	14.62	14.70	12.86	18.99	11.95	11.87	11.50	20.12
	5	17.03	15.58	15.47	18.59	16.90	15.88	15.52	19.56
	6	42.35	44.08	42.92	37.13	34.89	37.81	36.95	32.14
	7	27.89	26.93	27.95	25.61	21.60	19.56	21.33	19.08
	8	128.31	126.10	133.51	113.91	95.14	88.40	99.65	84.41
	9	34.55	36.04	37.98	33.25	44.15	46.49	50.53	40.68
	10	15.59	15.91	14.69	18.25	12.97	13.20	12.02	16.55
	11	14.10	14.10	13.76	17.80	13.14	13.38	12.67	17.42
	12	10.13	10.45	9.73	16.82	9.99	10.37	9.77	18.79

Daily ORDC Adders Average Values and Interval Duration								
YEAR	MONTH	DAY	PRICE_RS	PRICE_RDP	RS_CNT	RDP_CNT	RS_POS	RDP_POS
2023	12	1	\$ -	\$ -	0	0	80	90
2023	12	2	\$ -	\$ -	0	0	80	90
2023	12	3	\$ -	\$ -	0	0	80	90
2023	12	4	\$ -	\$ -	0	0	80	90
2023	12	5	\$ 0.02	\$ -	3	0	80	90
2023	12	6	\$ -	\$ -	0	0	80	90
2023	12	7	\$ -	\$ -	0	0	80	90
2023	12	8	\$ -	\$ -	0	0	80	90
2023	12	9	\$ -	\$ -	0	0	80	90
2023	12	10	\$ -	\$ -	0	0	80	90
2023	12	11	\$ -	\$ -	0	0	80	90
2023	12	12	\$ -	\$ -	0	0	80	90
2023	12	13	\$ -	\$ -	0	0	80	90
2023	12	14	\$ -	\$ -	0	0	80	90
2023	12	15	\$ -	\$ -	0	0	80	90
2023	12	16	\$ -	\$ -	0	0	80	90
2023	12	17	\$ -	\$ -	0	0	80	90
2023	12	18	\$ -	\$ -	0	0	80	90
2023	12	19	\$ -	\$ -	0	0	80	90
2023	12	20	\$ -	\$ 0.80	0	13	80	90
2023	12	21	\$ -	\$ -	0	0	80	90
2023	12	22	\$ -	\$ -	0	0	80	90
2023	12	23	\$ -	\$ -	0	0	80	90
2023	12	24	\$ -	\$ -	0	0	80	90
2023	12	25	\$ -	\$ -	0	0	80	90
2023	12	26	\$ -	\$ -	0	0	80	90
2023	12	27	\$ -	\$ -	0	0	80	90
2023	12	28	\$ -	\$ -	0	0	80	90
2023	12	29	\$ -	\$ -	0	0	80	90
2023	12	30	\$ 0.01	\$ -	3	0	80	90
2023	12	31	\$ -	\$ -	0	0	80	90

**Monthly Average of Ancillary Services Required MW**

year	month	ASMW_REGDN	ASMW_NSPIN	ASMW_RRS	ASMW_REGUP	ASMW_ECRS
2022	1	325	3,867	2,926	346	-
	2	388	4,267	2,950	372	-
	3	387	3,782	3,070	395	-
	4	372	4,069	3,014	373	-
	5	397	4,551	2,893	399	-
	6	339	4,197	2,694	372	-
	7	321	3,750	2,564	343	-
	8	347	3,592	2,572	348	-
	9	355	3,414	2,712	343	-
	10	327	4,404	2,893	343	-
	11	307	3,287	3,045	327	-
	12	318	3,687	3,030	351	-
2023	1	342	4,048	2,965	372	-
	2	420	4,243	3,022	400	-
	3	433	4,049	3,256	454	-
	4	405	4,262	3,102	400	-
	5	418	5,052	2,901	428	-
	6	376	3,275	2,676	408	2,073
	7	347	2,801	2,583	379	2,041
	8	323	2,207	2,566	389	2,127
	9	362	2,265	2,693	381	2,041
	10	399	2,467	2,950	409	1,784
	11	335	2,385	3,076	344	1,607
	12	339	3,092	3,053	366	1,847

Hourly Average of Ancillary Services Required MW

year	DELIVERY_HOUR	ASMW_REGDN	ASMW_NSPIN	ASMW_RRS	ASMW_REGUP	ASMW_ECRS
2022	1	364	3,535	2,910	219	-
	2	284	3,535	2,910	197	-
	3	241	3,483	2,942	206	-
	4	209	3,483	2,943	241	-
	5	208	3,483	2,943	297	-
	6	269	3,483	2,943	412	-
	7	232	4,067	2,832	526	-
	8	274	4,068	2,832	354	-
	9	411	4,068	2,832	367	-
	10	415	4,068	2,832	453	-
	11	425	4,195	2,745	490	-
	12	372	4,198	2,745	499	-
	13	339	4,235	2,745	479	-
	14	345	4,236	2,745	450	-
	15	359	4,086	2,872	432	-
	16	368	4,086	2,872	446	-
	17	377	4,086	2,872	497	-
	18	375	4,086	2,872	505	-
	19	393	3,875	2,876	424	-
	20	359	3,875	2,876	319	-
	21	389	3,875	2,876	241	-
	22	451	3,873	2,876	201	-
	23	468	3,860	2,910	198	-
	24	429	3,860	2,910	170	-
2023	1	372	2,816	2,954	227	1,447
	2	294	2,816	2,954	189	1,393
	3	248	3,101	2,987	214	1,462
	4	223	3,103	2,988	242	1,460
	5	219	3,103	2,988	297	1,431
	6	261	3,103	2,988	426	1,440
	7	233	3,558	2,883	521	1,598
	8	362	3,558	2,883	347	1,815
	9	592	3,558	2,883	340	2,104
	10	495	3,558	2,883	486	2,474
	11	421	3,668	2,778	530	2,305
	12	393	3,668	2,778	535	2,325
	13	385	3,687	2,778	522	2,267
	14	375	3,687	2,778	510	2,283
	15	404	3,620	2,908	499	2,331
	16	419	3,620	2,908	523	2,413
	17	424	3,620	2,908	606	2,359
	18	405	3,620	2,908	652	2,359
	19	397	3,147	2,905	546	2,172
	20	338	3,147	2,905	409	2,042
	21	376	3,147	2,905	275	1,864
	22	439	3,147	2,905	201	1,756
	23	472	3,068	2,954	192	1,612
	24	443	3,068	2,954	168	1,501

**Monthly Average Ancillary Services Price**

year	month	MCPC_REGDN	MCPC_NSPIN	MCPC_RRS	MCPC_REGUP	MCPC_ECRS
2022	1	\$ 6.15	\$ 5.07	\$ 8.39	\$ 11.56	\$ -
	2	\$ 9.60	\$ 16.07	\$ 12.93	\$ 17.69	\$ -
	3	\$ 17.94	\$ 12.43	\$ 18.67	\$ 22.69	\$ -
	4	\$ 13.88	\$ 19.17	\$ 18.04	\$ 20.99	\$ -
	5	\$ 18.03	\$ 51.85	\$ 31.29	\$ 38.71	\$ -
	6	\$ 7.01	\$ 23.22	\$ 22.48	\$ 24.71	\$ -
	7	\$ 9.52	\$ 54.81	\$ 61.26	\$ 72.27	\$ -
	8	\$ 6.45	\$ 17.89	\$ 14.80	\$ 22.36	\$ -
	9	\$ 6.93	\$ 9.67	\$ 7.32	\$ 12.85	\$ -
	10	\$ 3.89	\$ 14.20	\$ 5.65	\$ 9.55	\$ -
	11	\$ 3.63	\$ 9.58	\$ 4.19	\$ 8.53	\$ -
	12	\$ 8.42	\$ 38.40	\$ 40.31	\$ 42.73	\$ -
2023	1	\$ 5.69	\$ 4.69	\$ 4.00	\$ 7.27	\$ -
	2	\$ 12.99	\$ 5.79	\$ 3.72	\$ 7.58	\$ -
	3	\$ 6.42	\$ 8.01	\$ 6.24	\$ 12.47	\$ -
	4	\$ 7.65	\$ 8.03	\$ 6.12	\$ 12.52	\$ -
	5	\$ 4.74	\$ 11.87	\$ 4.03	\$ 7.66	\$ -
	6	\$ 8.20	\$ 45.87	\$ 38.57	\$ 47.00	\$ 107.44
	7	\$ 6.53	\$ 17.12	\$ 18.14	\$ 23.85	\$ 38.30
	8	\$ 99.16	\$ 80.61	\$ 132.73	\$ 215.17	\$ 276.73
	9	\$ 29.48	\$ 17.56	\$ 32.12	\$ 47.44	\$ 44.76
	10	\$ 6.59	\$ 8.23	\$ 10.82	\$ 17.38	\$ 16.78
	11	\$ 3.19	\$ 8.98	\$ 7.73	\$ 12.42	\$ 11.06
	12	\$ 2.60	\$ 2.81	\$ 2.50	\$ 3.91	\$ 3.28

Monthly Average A/S Cost per MWh Load

year	month	AScost_REGDN	AScost_NSPIN	AScost_RRS	AScost_REGUP	AScost_ECRS
2022	1	\$ 0.04	\$ 0.44	\$ 0.55	\$ 0.09	\$ -
	2	\$ 0.08	\$ 1.47	\$ 0.82	\$ 0.14	\$ -
	3	\$ 0.17	\$ 1.15	\$ 1.40	\$ 0.22	\$ -
	4	\$ 0.12	\$ 1.82	\$ 1.27	\$ 0.18	\$ -
	5	\$ 0.14	\$ 4.56	\$ 1.75	\$ 0.30	\$ -
	6	\$ 0.04	\$ 1.67	\$ 1.04	\$ 0.16	\$ -
	7	\$ 0.05	\$ 3.33	\$ 2.54	\$ 0.40	\$ -
	8	\$ 0.04	\$ 1.11	\$ 0.66	\$ 0.13	\$ -
	9	\$ 0.05	\$ 0.64	\$ 0.38	\$ 0.08	\$ -
	10	\$ 0.03	\$ 1.45	\$ 0.38	\$ 0.08	\$ -
	11	\$ 0.03	\$ 0.73	\$ 0.29	\$ 0.06	\$ -
	12	\$ 0.06	\$ 3.12	\$ 2.69	\$ 0.33	\$ -
2023	1	\$ 0.04	\$ 0.44	\$ 0.27	\$ 0.06	\$ -
	2	\$ 0.12	\$ 0.55	\$ 0.25	\$ 0.07	\$ -
	3	\$ 0.06	\$ 0.76	\$ 0.48	\$ 0.13	\$ -
	4	\$ 0.07	\$ 0.80	\$ 0.45	\$ 0.12	\$ -
	5	\$ 0.04	\$ 1.22	\$ 0.24	\$ 0.07	\$ -
	6	\$ 0.05	\$ 2.53	\$ 1.74	\$ 0.32	\$ 2.63
	7	\$ 0.04	\$ 0.75	\$ 0.73	\$ 0.14	\$ 1.23
	8	\$ 0.47	\$ 2.63	\$ 5.04	\$ 1.24	\$ 8.72
	9	\$ 0.18	\$ 0.67	\$ 1.45	\$ 0.30	\$ 1.53
	10	\$ 0.06	\$ 0.43	\$ 0.67	\$ 0.15	\$ 0.63
	11	\$ 0.02	\$ 0.49	\$ 0.55	\$ 0.10	\$ 0.41
	12	\$ 0.02	\$ 0.19	\$ 0.17	\$ 0.03	\$ 0.14

ERCOT-wide Cumulative PNM			
year	month	pnm	pnm_accum
2022	0	\$ -	\$ -
	1	\$ 2,245.58	\$ 2,245.58
	2	\$ 14,589.18	\$ 16,834.76
	3	\$ 4,492.68	\$ 21,327.44
	4	\$ 7,843.68	\$ 29,171.12
	5	\$ 25,120.79	\$ 54,291.91
	6	\$ 4,444.47	\$ 58,736.38
	7	\$ 61,835.52	\$ 120,571.90
	8	\$ 12,243.51	\$ 132,815.41
	9	\$ 4,218.01	\$ 137,033.42
	10	\$ 7,195.67	\$ 144,229.09
	11	\$ 5,637.30	\$ 149,866.39
	12	\$ 15,653.63	\$ 165,520.02
2023	0	\$ -	\$ -
	1	\$ 3,758.67	\$ 3,758.67
	2	\$ 3,066.65	\$ 6,825.32
	3	\$ 7,327.65	\$ 14,152.97
	4	\$ 3,963.19	\$ 18,116.16
	5	\$ 8,532.76	\$ 26,648.92
	6	\$ 30,746.31	\$ 57,395.23
	7	\$ 15,736.44	\$ 73,131.67
	8	\$ 125,626.42	\$ 198,758.09
	9	\$ 46,968.45	\$ 245,726.54
	10	\$ 6,305.54	\$ 252,032.08
	11	\$ 7,639.84	\$ 259,671.92
	12	\$ 4,296.20	\$ 263,968.12



DA vs. RT Load Forecast Error by Hour Ending							
year	month	HE_1_4	HE_13_16	HE_17_20	HE_21_24	HE_5_8	HE_9_12
2022	1	(408)	171	670	86	190	25
	2	(1,031)	155	689	(222)	(62)	442
	3	(897)	(126)	(168)	(643)	(588)	(395)
	4	(946)	302	(321)	(854)	(1,173)	(532)
	5	(1,877)	992	(191)	(1,445)	(1,812)	(395)
	6	(1,009)	1,448	1,149	(347)	(431)	530
	7	(532)	1,469	1,099	(137)	(403)	769
	8	(318)	1,551	1,167	279	(381)	650
	9	245	1,053	940	390	96	1,245
	10	245	1,496	331	247	368	1,351
	11	(204)	286	730	449	441	698
	12	(1,011)	428	278	(233)	(269)	229
2023	1	33	392	136	210	732	1,397
	2	(28)	1,497	1,206	666	1,005	1,480
	3	(484)	459	208	89	750	931
	4	(1,127)	362	252	(282)	(373)	534
	5	(909)	1,207	1,088	(363)	(998)	467
	6	(68)	2,778	1,439	415	(586)	1,530
	7	22	3,009	1,488	468	(224)	1,085
	8	45	1,604	872	994	(355)	802
	9	(320)	1,185	417	(82)	(589)	338
	10	(322)	1,539	1,233	109	(527)	752
	11	(207)	268	863	73	186	101
	12	(632)	(450)	235	(80)	(806)	(943)

Monthly Average of Wind Generation by Hour Ending							
year	month	HE_1_4	HE_13_16	HE_17_20	HE_21_24	HE_5_8	HE_9_12
2022	1	13,020	9,623	9,868	12,555	13,127	10,415
	2	14,195	10,245	11,028	13,744	13,920	11,206
	3	16,027	13,581	13,844	15,591	16,250	14,236
	4	17,675	15,266	15,674	16,702	16,996	16,211
	5	19,060	14,380	16,476	18,635	17,225	15,650
	6	16,762	10,737	13,012	15,837	13,740	11,588
	7	15,609	7,947	11,386	14,680	12,513	9,484
	8	10,766	6,175	8,856	10,584	8,506	6,596
	9	11,017	5,597	6,896	10,717	8,643	5,946
	10	11,757	8,113	9,031	11,725	10,439	8,063
	11	13,853	11,574	12,093	14,140	12,744	10,994
	12	12,260	10,846	10,713	12,593	12,069	11,133
2023	1	16,786	12,978	13,256	16,258	15,896	13,255
	2	15,935	14,322	15,239	17,307	15,026	13,552
	3	16,983	12,878	13,946	16,760	15,530	13,978
	4	16,756	12,031	13,207	16,187	15,018	12,761
	5	12,744	7,265	10,625	13,140	9,807	7,209
	6	14,285	8,535	10,879	13,859	11,975	9,609
	7	16,218	8,723	10,953	14,729	13,006	9,683
	8	14,147	7,705	9,874	12,837	11,131	8,875
	9	13,994	6,223	7,888	13,447	11,182	8,244
	10	14,077	10,071	10,516	13,441	12,740	10,486
	11	12,510	9,029	9,928	13,033	11,412	9,478
	12	13,984	11,534	11,641	14,558	12,979	11,017

Monthly Average of Solar Generation by Hour Ending							
year	month	HE_1_4	HE_13_16	HE_17_20	HE_21_24	HE_5_8	HE_9_12
2022	1	3.3	5,290.8	1,314.4	3.4	9.3	4,155.3
	2	0.5	5,882.4	2,034.5	0.6	45.8	4,746.8
	3	0.2	5,974.1	3,214.2	0.2	69.8	5,067.0
	4	3.3	6,315.0	4,406.9	16.0	69.2	4,384.8
	5	2.0	7,466.6	5,237.1	43.8	260.4	5,834.7
	6	0.6	8,347.9	6,137.0	88.6	438.8	7,273.4
	7	0.1	8,789.3	6,477.1	92.3	363.2	7,994.0
	8	1.3	7,657.8	4,939.1	24.1	135.2	6,424.0
	9	0.1	8,755.9	5,124.3	1.0	53.3	7,079.6
	10	0.2	7,427.7	3,253.4	1.4	11.9	5,662.9
	11	0.2	5,213.3	951.1	2.1	82.4	4,370.7
	12	0.3	4,609.4	726.6	0.4	21.8	4,084.6
2023	1	0.3	5,954.5	1,303.5	0.7	14.6	4,959.9
	2	0.9	5,984.7	1,750.2	1.0	64.5	5,072.6
	3	0.2	7,665.3	3,657.6	0.4	67.8	5,196.4
	4	0.2	8,939.2	5,678.3	7.1	130.2	6,575.6
	5	0.2	10,047.5	6,026.7	36.3	350.0	7,903.1
	6	0.3	11,237.5	7,807.2	107.4	563.2	9,356.5
	7	0.5	11,950.8	9,016.3	114.9	442.2	10,019.0
	8	0.3	12,377.6	8,266.7	25.0	237.9	10,464.6
	9	0.2	11,508.5	6,593.0	0.4	73.3	8,924.6
	10	0.1	9,743.6	4,456.3	0.7	13.8	6,723.8
	11	0.4	7,750.9	1,479.5	0.4	125.5	6,606.1
	12	0.0	8,837.9	1,248.3	0.1	59.6	7,972.6

RT Congestion Constraint Rankings - Top 10 Constraints by Binding Frequency and Top 10 Constraints by Total Congestion Rent																
CATEGORY	YEAR	CONSTRAINT	RANKVAR	RANK	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
FREQ_EXIST	2023	NORTH EDINBURG LOBO GTC (NE LOB)	23821	1	1585	2536	2252	1723	2319	2288	2934	2356	938	2544	1799	547
FREQ_EXIST	2023	BEARKAT GTC (BEARKT)	13083	2	4477	2614	3765	2223	3	1	0	0	0	0	0	0
FREQ_EXIST	2023	HAMILT MAVERI1_1 (HAMILTON-MAVERICK)	11044	3	1221	1273	1449	2499	391	514	946	1455	343	1	178	774
FREQ_EXIST	2023	PANHANDLE GTC (PNHNDL)	8147	4	0	1653	3070	783	0	0	0	0	36	1378	774	453
FREQ_EXIST	2023	WEST TEXAS EXPORT GTC (WESTEX)	7666	5	1395	1111	948	346	56	420	268	99	288	659	1088	988
FREQ_EXIST	2023	BURNS RIOHONDO_1 (RIOHONDO-MV_BURNS)	7231	6	561	924	1614	422	255	937	607	778	584	351	20	178
FREQ_EXIST	2023	VALLEY EXPORT GTC (VALEXP)	7153	7	446	685	328	725	600	262	237	196	120	982	1794	778
FREQ_EXIST	2023	CATARI_PILONC1_1 (PILONCIL-CATARINA)	6248	8	1253	497	1052	574	214	262	0	0	207	442	227	1520
FREQ_EXIST	2023	6036_A (TKWSW-MGSES)	6217	9	105	212	274	114	93	262	302	988	962	915	1089	901
FREQ_EXIST	2023	6437_F (SCRCV-KNAPP)	5780	10	0	132	116	23	7	937	1825	1647	853	100	98	42
TOP10_RENT	2023	PAWNEE SPRUCE_1 (PAWNEE-CALAVERS)	\$ 173.24	1	\$ 2.80	\$ 3.15	\$ 0.43	\$ 0.01	\$ 0.33	\$ 17.74	\$ 21.16	\$ 97.17	\$ 30.20	\$ -	\$ 0.01	\$ 0.24
TOP10_RENT	2023	STP-WAP LINES (STP-WAP)	\$ 127.63	2	\$ -	\$ 0.09	\$ -	\$ 0.01	\$ 2.40	\$ 3.09	\$ 20.67	\$ 101.35	\$ 0.03	\$ -	\$ -	\$ -
TOP10_RENT	2023	6036_A (TKWSW-MGSES)	\$ 125.09	3	\$ 0.63	\$ 0.54	\$ 4.19	\$ 3.08	\$ 0.86	\$ 3.11	\$ 3.60	\$ 18.23	\$ 14.46	\$ 22.29	\$ 23.00	\$ 31.10
TOP10_RENT	2023	WEST TEXAS EXPORT GTC (WESTEX)	\$ 92.08	4	\$ 17.01	\$ 9.87	\$ 10.76	\$ 3.44	\$ 0.21	\$ 5.51	\$ 3.41	\$ 1.37	\$ 3.16	\$ 7.04	\$ 17.21	\$ 13.08
TOP10_RENT	2023	MDSSW XFMR5 (MDSSW-MDSSW)	\$ 85.35	5	\$ 3.79	\$ 10.99	\$ 57.66	\$ 7.53	\$ 5.38	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
TOP10_RENT	2023	NORTH EDINBURG LOBO GTC (NE LOB)	\$ 71.10	6	\$ 4.19	\$ 6.47	\$ 6.94	\$ 3.60	\$ 6.77	\$ 7.06	\$ 9.91	\$ 9.28	\$ 3.90	\$ 6.63	\$ 4.99	\$ 1.37
TOP10_RENT	2023	HAMILT MAVERI1_1 (HAMILTON-MAVERICK)	\$ 67.81	7	\$ 1.66	\$ 3.13	\$ 3.77	\$ 6.76	\$ 1.00	\$ 9.96	\$ 16.65	\$ 22.25	\$ 1.96	\$ 0.00	\$ 0.12	\$ 0.57
TOP10_RENT	2023	BURNS RIOHONDO_1 (RIOHONDO-MV_BURNS)	\$ 62.69	8	\$ 2.12	\$ 2.98	\$ 13.91	\$ 0.90	\$ 0.99	\$ 18.72	\$ 2.72	\$ 4.39	\$ 13.89	\$ 1.24	\$ 0.03	\$ 0.79
TOP10_RENT	2023	6095_D (LMESA-JPPOI)	\$ 49.35	9	\$ 1.67	\$ 1.61	\$ 0.09	\$ 0.65	\$ 1.29	\$ 0.31	\$ 0.00	\$ 0.16	\$ 0.07	\$ 15.46	\$ 15.88	\$ 12.15
TOP10_RENT	2023	235_A (SJNSW-JEWET)	\$ 45.78	10	\$ -	\$ -	\$ -	\$ -	\$ 0.00	\$ 1.97	\$ 3.56	\$ 39.35	\$ 0.88	\$ 0.01	\$ -	\$ -

MONTH	RENT_TOTAL
1	145.61
2	154.48
3	260.24
4	174.51
5	88.05
6	183.76
7	176.15
8	553.47
9	257.01
10	169.08
11	110.33
12	127.52
Sum-Total	2400.22

DA Congestion Constraint Rankings - Top 10 Constraints by Binding Frequency and Top 10 Constraints by Total Congestion Rent																
category	year	item	rankvar	rank	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
FREQ_EXIST	2023	ASHERT_CATARI1_1 (ASHERTON-CATARINA)	5,216	1	592	649	707	618	514	397	217	196	232	281	319	494
FREQ_EXIST	2023	6144_A (BSPRW-STASW)	4,390	2	450	399	281	374	410	326	319	327	353	402	399	350
FREQ_EXIST	2023	CONCHO_SANW0_1 (CONCHO-SANW)	4,344	3	195	165	365	427	388	430	438	395	428	525	325	263
FREQ_EXIST	2023	PUEBLO_XFMRS (PUEBLO-PUEBLO)	4,081	4	358	568	450	280	439	406	390	350	214	128	167	331
FREQ_EXIST	2023	CATARI_PILONC1_1 (PILONCIL-CATARINA)	3,709	5	500	462	510	416	182	125	96	182	243	191	341	461
FREQ_EXIST	2023	NORTH_EDINBURG_LOBO_GTC (NE_LOB)	3,481	6	200	275	365	203	349	358	372	271	157	377	352	202
FREQ_EXIST	2023	LARDVN_LASCRU1_1 (LARDVNTH-LASCRUCE)	3,404	7	251	276	352	239	196	410	420	352	116	274	245	273
FREQ_EXIST	2023	LPLMK_LPLNE_1 (LPLMK-LPLNE)	3,366	8	316	400	603	509	352	104	87	154	126	248	275	192
FREQ_EXIST	2023	LPLBR_BRT1 (LPLBR-LPLBR)	3,093	9	48	100	59	371	430	273	477	406	410	341	20	158
FREQ_EXIST	2023	6471_C (MGSES-NAVIG)	3,015	10	-	-	-	9	402	401	392	390	395	136	355	535
TOP10_RENT	2023	PAWNEE_SPRUCE_1 (PAWNEE-CALAVERS)	\$ 112.88	1	\$ 4.36	\$ 4.27	\$ 0.72	\$ 0.20	\$ 1.06	\$ 8.70	\$ 15.11	\$ 63.93	\$ 11.01	\$ 2.17	\$ 0.36	\$ 0.99
TOP10_RENT	2023	MDSSW_XFMR (MDSSW-MDSSW)	\$ 79.47	2	\$ 1.47	\$ 10.79	\$ 45.85	\$ 17.89	\$ 3.47	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -	\$ -
TOP10_RENT	2023	WEST_TEXAS_EXPORT_GTC (WESTEX)	\$ 73.61	3	\$ 12.91	\$ 11.98	\$ 9.60	\$ 3.47	\$ 1.29	\$ 2.26	\$ 1.51	\$ 0.27	\$ 1.98	\$ 6.18	\$ 11.53	\$ 10.62
TOP10_RENT	2023	6036_A (TKWSW-MGSES)	\$ 71.50	4	\$ 0.07	\$ -	\$ 0.13	\$ 0.28	\$ 0.02	\$ 0.79	\$ 1.08	\$ 7.92	\$ 10.98	\$ 14.42	\$ 14.35	\$ 21.45
TOP10_RENT	2023	NORTH_EDINBURG_LOBO_GTC (NE_LOB)	\$ 66.63	5	\$ 3.86	\$ 4.95	\$ 8.64	\$ 3.55	\$ 6.50	\$ 6.21	\$ 8.87	\$ 7.21	\$ 3.76	\$ 6.62	\$ 4.17	\$ 2.29
TOP10_RENT	2023	BURNS_RIOHONDO_1 (RIOHONDO-MV_BURNS)	\$ 65.08	6	\$ 4.70	\$ 4.11	\$ 17.60	\$ 4.44	\$ 0.95	\$ 11.92	\$ 5.11	\$ 5.47	\$ 5.62	\$ 3.16	\$ 1.07	\$ 0.93
TOP10_RENT	2023	STP-WAP_LINES (STP-WAP)	\$ 55.88	7	\$ -	\$ 0.14	\$ 0.23	\$ -	\$ 1.34	\$ 3.18	\$ 10.29	\$ 39.70	\$ 1.01	\$ -	\$ -	\$ -
TOP10_RENT	2023	LPLMK_LPLNE_1 (LPLMK-LPLNE)	\$ 46.77	8	\$ 2.09	\$ 4.42	\$ 13.23	\$ 9.27	\$ 4.47	\$ 0.40	\$ 0.90	\$ 1.99	\$ 1.33	\$ 3.83	\$ 3.33	\$ 1.50
TOP10_RENT	2023	HAMILT_MAVERI1_1 (HAMILTON-MAVERICK)	\$ 41.38	9	\$ 0.88	\$ 1.73	\$ 4.41	\$ 8.63	\$ 1.15	\$ 5.67	\$ 9.32	\$ 6.87	\$ 2.15	\$ 0.04	\$ 0.13	\$ 0.40
TOP10_RENT	2023	6471_C (MGSES-NAVIG)	\$ 40.83	10	\$ -	\$ -	\$ -	\$ 0.13	\$ 3.22	\$ 4.77	\$ 3.90	\$ 4.66	\$ 4.24	\$ 1.95	\$ 6.92	\$ 11.04

Top 10 CRR Pairs Ranked by Monthly Auction Values - Top 10 PTP Obligations by Total Transaction Values and Top 10 PTP Options by Total Transaction Values																
ptr_option	year	pair	total_value	rank	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
N	2023	HB WEST-LZ WEST	\$ 82.42	1	\$ 1.97	\$ 5.50	\$ 5.86	\$ 7.71	\$ 9.85	\$ 7.68	\$ 5.06	\$ 4.11	\$ 6.45	\$ 7.77	\$ 10.33	\$ 10.12
N	2023	HB NORTH-HB HOUSTON	\$ 29.45	2	\$ 0.24	\$ 0.31	\$ 2.82	\$ 4.96	\$ 4.97	\$ 4.68	\$ 1.16	\$ 2.23	\$ 3.07	\$ 3.49	\$ 1.13	\$ 0.38
N	2023	HB HOUSTON-LZ HOUSTON	\$ 15.04	3	\$ 0.38	\$ 0.54	\$ 0.52	\$ 1.22	\$ 2.07	\$ 2.97	\$ 1.12	\$ 1.26	\$ 1.66	\$ 1.77	\$ 0.95	\$ 0.58
N	2023	HB NORTH-LZ NORTH	\$ 13.91	4	\$ 0.81	\$ 0.73	\$ 0.31	\$ 0.44	\$ 0.89	\$ 2.05	\$ 2.39	\$ 1.57	\$ 1.88	\$ 1.23	\$ 0.85	\$ 0.77
N	2023	AEEC-LZ WEST	\$ 11.14	5	\$ 1.13	\$ 0.91	\$ 0.59	\$ 0.79	\$ 0.84	\$ 0.91	\$ 0.42	\$ 0.32	\$ 1.12	\$ 0.74	\$ 1.80	\$ 1.57
N	2023	COL_COLETOG1-HB SOUTH	\$ 8.02	6	\$ 0.74	\$ 0.57	\$ -	\$ 0.08	\$ 0.27	\$ 0.88	\$ 1.15	\$ 0.97	\$ 0.98	\$ 1.00	\$ 0.67	\$ 0.70
N	2023	HB PAN-HB WEST	\$ 7.07	7	\$ 0.00	\$ 0.16	\$ 0.15	\$ 0.89	\$ 0.26	\$ 0.41	\$ 0.03	\$ 0.03	\$ 0.21	\$ 0.70	\$ 1.23	\$ 2.99
N	2023	HB SOUTH-HB NORTH	\$ 6.40	8	\$ 0.95	\$ 0.41	\$ 0.16	\$ -	\$ -	\$ 0.02	\$ -	\$ 1.99	\$ 2.88	\$ -	\$ -	\$ 0.00
N	2023	MIRASOLE_GEN-HB SOUTH	\$ 4.96	9	\$ 0.66	\$ 0.26	\$ 0.37	\$ 1.40	\$ 0.82	\$ 0.83	\$ 0.56	\$ 0.02	\$ 0.01	\$ -	\$ 0.02	\$ 0.01
N	2023	WAP_WAP_G7-HB HOUSTON	\$ 4.66	10	\$ 0.16	\$ 0.04	\$ 1.09	\$ 0.14	\$ 1.04	\$ 0.96	\$ 0.14	\$ 0.12	\$ 0.14	\$ 0.44	\$ 0.21	\$ 0.20
Y	2023	ELB_ELBCREEK-RSK RN	\$ 13.06	1	\$ 0.68	\$ 1.14	\$ 1.88	\$ 4.89	\$ 2.60	\$ 0.80	\$ 0.10	\$ 0.03	\$ 0.17	\$ 0.34	\$ 0.35	\$ 0.05
Y	2023	HB WEST-LZ WEST	\$ 8.30	2	\$ 1.81	\$ 0.78	\$ 0.04	\$ 1.08	\$ 0.86	\$ 0.76	\$ 0.04	\$ 1.27	\$ 1.28	\$ 0.11	\$ 0.12	\$ 0.16
Y	2023	LV1A_LV1B-LZ CPS	\$ 5.04	3	\$ 0.55	\$ 0.77	\$ 0.35	\$ 0.95	\$ 0.75	\$ 0.20	\$ 0.19	\$ 0.17	\$ 0.01	\$ 0.31	\$ 0.45	\$ 0.35
Y	2023	CEDROHI_CHW1-LZ CPS	\$ 4.61	4	\$ 0.42	\$ 0.63	\$ 0.43	\$ 0.42	\$ 0.64	\$ 0.59	\$ 0.31	\$ 0.21	\$ 0.07	\$ 0.35	\$ 0.28	\$ 0.27
Y	2023	RSK_RN-ELB_ELBCREEK	\$ 4.19	5	\$ 0.20	\$ 0.57	\$ 1.12	\$ 0.62	\$ 1.24	\$ 0.09	\$ 0.04	\$ 0.06	\$ 0.05	\$ 0.14	\$ 0.06	\$ 0.00
Y	2023	BORDAS_345-HB SOUTH	\$ 3.53	6	\$ 0.19	\$ 0.23	\$ 0.74	\$ 0.16	\$ 1.55	\$ 0.02	\$ 0.04	\$ 0.21	\$ 0.12	\$ 0.07	\$ 0.16	\$ 0.03
Y	2023	HB NORTH-LZ NORTH	\$ 3.42	7	\$ 0.13	\$ 0.57	\$ 0.41	\$ 0.24	\$ 0.21	\$ 0.34	\$ 0.14	\$ 0.25	\$ 0.29	\$ 0.20	\$ 0.22	\$ 0.43
Y	2023	SWTWN4_WND45-LZ CPS	\$ 3.26	8	\$ 0.14	\$ 0.12	\$ 0.33	\$ 0.95	\$ 0.73	\$ 0.32	\$ 0.11	\$ 0.08	\$ 0.09	\$ 0.27	\$ 0.09	\$ 0.03
Y	2023	RIONOG_ST1-LZ CPS	\$ 3.15	9	\$ -	\$ -	\$ 0.11	\$ 0.10	\$ 0.76	\$ 0.89	\$ 0.31	\$ 0.17	\$ 0.25	\$ 0.35	\$ 0.12	\$ 0.08
Y	2023	HB SOUTH-LZ SOUTH	\$ 3.10	10	\$ 0.16	\$ 0.20	\$ 0.15	\$ 0.37	\$ 0.42	\$ 0.60	\$ 0.09	\$ 0.40	\$ 0.28	\$ 0.32	\$ 0.08	\$ 0.05